

Candia School District
Henry W. Moore School
12 Deerfield Road, Candia, NH 03034
(603) 483-2251
candia.sau15.net

Becky L. Wing
Principal

Dorothy Franchini
Assistant Principal

Stacey Eaton
Director of Student Services

January 9, 2026 (results received 1/8/2026)

Dear Moore School Families,

We are writing to let you know that the Henry W. Moore School recently completed testing for lead in drinking water. This is part of an ongoing effort related to New Hampshire state law RSA 485:17-a, which requires school and child care facilities to test for lead in drinking water and to act when lead is found at levels at or above 5 parts per billion (ppb).

Lead is a toxic heavy metal that has a range of adverse health effects if inhaled or swallowed. Lead rarely occurs naturally in New Hampshire's drinking water sources (groundwater or surface water) and typically enters drinking water due to the wearing away of piping, faucets, fixtures and other plumbing materials.

Because lead is tasteless, odorless and colorless in drinking water, testing is the only way to learn whether lead is present. It is important to sample each faucet or water fountain that is used for drinking or food prep because test results can vary between locations.

During recent testing, 25 outlets were tested drinking water outlets (e.g., drinking fountains, classroom faucets, kitchen sinks), with a total of 5 outlet samples are testing at or above 5 ppb, the level where action must be taken.

We have removed access to these outlets until the problem can be corrected. The table below shows a list of all the tested outlets, their locations, sample results and our planned remediation.


Outlet Number	Location	Sample Result (ppb)	Planned Remediation
10	Room 32 Kitchen	20.8	Filtration and plumbing conversion from copper to PVC
11	Room 32 Kitchen	5.33	Filtration and plumbing conversion from copper to PVC
12	Room 32 Kitchen	12.3	Filtration and plumbing conversion from copper to PVC

16	Classroom Faucet (Room 56)	9.72	Permanently posted for no drinking / hand wash only
25	Men's Staff Bathroom Faucet (Room 42)	5.03	Permanently posted for no drinking / hand wash only

All sample results and additional resources from the New Hampshire Department of Environmental Services (NHDES) can be viewed at gettheleadoutnh.org.

Sincerely,
Henry Moore School
Director of Maintenance
Donald Beaupre

Scan the QR Code for information and resources for parents on the health effects of lead exposure.



Or visit the [NH Department of Health and Human Services webpage](#) learn more.

